

TOWNSHIP OF MALAHIDE

ADDENDUM NO. 1

RE: TENDER CLOSING EXTENSION

Due to a seasonally high water table, the tender period has been extended by 7 weeks, and will be received at the office of the Clerk, 87 John Street South, Aylmer, until **12:00pm noon on Thursday 16 May 2019.**

The Township will arrange for test pits to be dug on **Wednesday 8 May 2019 at 9:00am.**

RE: GEOTECHNICAL INVESTIGATION

The DRAFT Geotechnical Engineering Report prepared by Golder dated March, 2019 is enclosed with this addendum and shall accompany the Contract Documents.

RE: QUESTIONS RECEIVED

Re: Item 1.8. Is the Municipality supplying everything from main to meter pit as well as meter pit or where do we have to supply to?

Only the meter pit will be supplied by the Township. Lump sum price for item 1.8 shall include installation of the meter pit, and connection to the existing service. Supply and installation of the new service lead from the main to the meter pit is to be included in Item 1.7i.

1740 - Addendum No. 1
Page 1 of 1

Signature of Tenderer
(Affix Company Seal)

26 March 2019

CYRIL J. DEMEYERE LIMITED,
CONSULTING ENGINEERS,
P.O. BOX 460, 261 BROADWAY,
TILLSONBURG, ONTARIO. N4G 4H8
(519)688-1000 (FAX)842-3235